



October 13, 2010

KEVIN KEMPLIN  
BOLIVAR WSC  
PO BOX 1789  
SANGER, TX 76266

TEL:  
FAX

RE: WS 0610049 LCR

COC ID.: 95867

Order No.: 1010081

Dear KEVIN KEMPLIN:

On 10/1/2010, LCRA Environmental Laboratory Services (ELS) received 20 sample(s) for analyses under Lab Order No. 1010081. This final report provides results related only to the sample(s) as received for the above referenced lab order number.

ELS is accredited under the National Environmental Laboratory Accreditation Program (NELAP) and certifies that all reported results meet NELAP requirements, unless otherwise noted. The Case Narrative provides explanations for any deviations, additions to, or exclusions from the method requirements.

This report contains a total of 5 pages (including the cover letter) and may not be reproduced, except in full, without written approval from ELS.

Thank you for selecting ELS for your analytical needs. If you have questions regarding this report, please contact us at (512) 356-6022. We look forward to assisting you again.

Sincerely,

Sandra Green  
Project Manager

Certificate: T104704218-10-2



## Final Analysis Report

LCRA Environmental Laboratory Services

Date: 13-Oct-10

<b>CLIENT:</b>	BOLIVAR WSC	<b>ICPMS METALS IN DRINKING WATER E200.8</b>
<b>Project:</b>	WS 0610049 LCR	
<b>Lab Order:</b>	1010081	<b>Matrix:</b> Drinking Water

Lab ID:	Client Sample ID:			Tag No:	Date Collected:	Date Received:	
1010081-001	508 PECAN CREEK TR			0605	9/28/2010 6:10:00 AM	10/1/2010 9:00:00 AM	
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed
Copper	0.00531		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 9:34:18 PM
Lead	0.000526	J	0.015	0.00102	mg/L	1	10/8/2010 9:34:18 PM
Lab ID:	Client Sample ID:			Tag No:	Date Collected:	Date Received:	
1010081-002	5206 HOPKINS RD			0605	9/29/2010 5:48:00 AM	10/1/2010 9:00:00 AM	
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed
Copper	0.00147		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 9:37:03 PM
Lead	0.000200	J	0.015	0.00102	mg/L	1	10/8/2010 9:37:03 PM
Lab ID:	Client Sample ID:			Tag No:	Date Collected:	Date Received:	
1010081-003	6110 CANYON RD			0605	9/28/2010 8:00:00 AM	10/1/2010 9:00:00 AM	
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed
Copper	0.00409		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 9:39:47 PM
Lead	0.000548	J	0.015	0.00102	mg/L	1	10/8/2010 9:39:47 PM
Lab ID:	Client Sample ID:			Tag No:	Date Collected:	Date Received:	
1010081-004	6252 MICHAEL RD			0605	9/29/2010 6:10:00 AM	10/1/2010 9:00:00 AM	
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed
Copper	0.00280		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 9:42:32 PM
Lead	0.000496	J	0.015	0.00102	mg/L	1	10/8/2010 9:42:32 PM
Lab ID:	Client Sample ID:			Tag No:	Date Collected:	Date Received:	
1010081-005	6612 FM 2450			0605	9/28/2010 6:58:00 AM	10/1/2010 9:00:00 AM	
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed
Copper	0.0222		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 9:45:17 PM
Lead	0.00230		0.015	0.00102	mg/L	1	10/8/2010 9:45:17 PM

## Qualifiers:

A Not Available for Accreditation	B Analyte Detected in Method Blank
E Value Above Quantitation Range	H Holding Time Exceeded
J Analyte Detected Below Quantitation Limits	N Not Accredited
S Spike Recovery Outside Recovery Limits	X Value Exceeds Maximum Contaminant Level (MCL)

PQL: Practical Quantitation Limit

## LCRA Environmental Laboratory Services

Date: 13-Oct-10

<b>CLIENT:</b>	BOLIVAR WSC	<b>ICPMS METALS IN DRINKING WATER E200.8</b>
<b>Project:</b>	WS 0610049 LCR	
<b>Lab Order:</b>	1010081	<b>Matrix:</b> Drinking Water

Lab ID:	Client Sample ID:			Tag No:	Date Collected:	Date Received:	
1010081-006	6981 LOIS RD			0605	9/29/2010 6:38:00 AM	10/1/2010 9:00:00 AM	
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.00262		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 9:48:01 PM
Lead	0.000110	J	0.015	0.00102	mg/L	1	10/8/2010 9:48:01 PM

Lab ID:	Client Sample ID:			Tag No:	Date Collected:	Date Received:	
1010081-007	7546 FM 1173			0605	9/28/2010 5:38:00 AM	10/1/2010 9:00:00 AM	
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.0254		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 9:50:46 PM
Lead	0.00309		0.015	0.00102	mg/L	1	10/8/2010 9:50:46 PM

Lab ID:	Client Sample ID:			Tag No:	Date Collected:	Date Received:	
1010081-008	7705 W RECTOR RD			0605	9/28/2010 6:12:00 AM	10/1/2010 9:00:00 AM	
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.00234		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 9:53:30 PM
Lead	0.000407	J	0.015	0.00102	mg/L	1	10/8/2010 9:53:30 PM

Lab ID:	Client Sample ID:			Tag No:	Date Collected:	Date Received:	
1010081-009	782 E LONE OAK FM 3005			0605	9/29/2010 7:10:00 AM	10/1/2010 9:00:00 AM	
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.0337		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 9:56:14 PM
Lead	0.00431		0.015	0.00102	mg/L	1	10/8/2010 9:56:14 PM

Lab ID:	Client Sample ID:			Tag No:	Date Collected:	Date Received:	
1010081-010	8311 SHAW RD			0605	9/28/2010 7:40:00 AM	10/1/2010 9:00:00 AM	
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.0614		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 10:04:29 PM
Lead	0.00849		0.015	0.00102	mg/L	1	10/8/2010 10:04:29 PM

## Qualifiers:

A Not Available for Accreditation

E Value Above Quantitation Range

J Analyte Detected Below Quantitation Limits

S Spike Recovery Outside Recovery Limits

B Analyte Detected in Method Blank

H Holding Time Exceeded

N Not Accredited

X Value Exceeds Maximum Contaminant Level (MCL)

PQL: Practical Quantitation Limit

## LCRA Environmental Laboratory Services

Date: 13-Oct-10

<b>CLIENT:</b>	BOLIVAR WSC	<b>ICPMS METALS IN DRINKING WATER E200.8</b>
<b>Project:</b>	WS 0610049 LCR	
<b>Lab Order:</b>	1010081	<b>Matrix:</b> Drinking Water

Lab ID:	Client Sample ID:	Tag No:	Date Collected:	Date Received:			
1010081-011	10922 REIK RD	0605	9/28/2010 6:00:00 AM	10/1/2010 9:00:00 AM			
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.0249		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 10:12:43 PM
Lead	0.00279		0.015	0.00102	mg/L	1	10/8/2010 10:12:43 PM

Lab ID:	Client Sample ID:	Tag No:	Date Collected:	Date Received:			
1010081-012	16199 FM 455 W	0605	9/29/2010 5:21:00 AM	10/1/2010 9:00:00 AM			
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.00149		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 10:15:28 PM
Lead	0.000073	J	0.015	0.00102	mg/L	1	10/8/2010 10:15:28 PM

Lab ID:	Client Sample ID:	Tag No:	Date Collected:	Date Received:			
1010081-013	2555 HULING RD	0605	9/29/2010 7:38:00 AM	10/1/2010 9:00:00 AM			
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.000603	J	1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 10:18:13 PM
Lead	< 0.000043		0.015	0.00102	mg/L	1	10/8/2010 10:18:13 PM

Lab ID:	Client Sample ID:	Tag No:	Date Collected:	Date Received:			
1010081-014	2752 SOUTH BRANCH RD	0605	9/28/2010 5:25:00 AM	10/1/2010 9:00:00 AM			
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.00167		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 10:20:58 PM
Lead	0.000076	J	0.015	0.00102	mg/L	1	10/8/2010 10:20:58 PM

Lab ID:	Client Sample ID:	Tag No:	Date Collected:	Date Received:			
1010081-015	2850 FM 2848	0605	9/28/2010 5:42:00 AM	10/1/2010 9:00:00 AM			
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.00145		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 10:23:42 PM
Lead	0.000065	J	0.015	0.00102	mg/L	1	10/8/2010 10:23:42 PM

**Qualifiers:**

A Not Available for Accreditation

E Value Above Quantitation Range

J Analyte Detected Below Quantitation Limits

S Spike Recovery Outside Recovery Limits

B Analyte Detected in Method Blank

H Holding Time Exceeded

N Not Accredited

X Value Exceeds Maximum Contaminant Level (MCL)

PQL: Practical Quantitation Limit

## LCRA Environmental Laboratory Services

Date: 13-Oct-10

<b>CLIENT:</b>	BOLIVAR WSC	<b>ICPMS METALS IN DRINKING WATER E200.8</b>
<b>Project:</b>	WS 0610049 LCR	
<b>Lab Order:</b>	1010081	<b>Matrix:</b> Drinking Water

Lab ID:	Client Sample ID:	Tag No:	Date Collected:	Date Received:			
1010081-016	3185 COWLING RD	0605	9/29/2010 7:12:00 AM	10/1/2010 9:00:00 AM			
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.00508		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 10:26:27 PM
Lead	0.000777	J	0.015	0.00102	mg/L	1	10/8/2010 10:26:27 PM

Lab ID:	Client Sample ID:	Tag No:	Date Collected:	Date Received:			
1010081-017	10874 FM 2450	0605	9/29/2010 7:05:00 AM	10/1/2010 9:00:00 AM			
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.0123		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 10:29:12 PM
Lead	0.00139		0.015	0.00102	mg/L	1	10/8/2010 10:29:12 PM

Lab ID:	Client Sample ID:	Tag No:	Date Collected:	Date Received:			
1010081-018	4145 CHISUM RD	0605	9/28/2010 6:30:00 AM	10/1/2010 9:00:00 AM			
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.00195		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 10:31:56 PM
Lead	0.000075	J	0.015	0.00102	mg/L	1	10/8/2010 10:31:56 PM

Lab ID:	Client Sample ID:	Tag No:	Date Collected:	Date Received:			
1010081-019	501 S LEE ST	0605	9/28/2010 5:49:00 AM	10/1/2010 9:00:00 AM			
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.00151		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 10:34:41 PM
Lead	0.000069	J	0.015	0.00102	mg/L	1	10/8/2010 10:34:41 PM

Lab ID:	Client Sample ID:	Tag No:	Date Collected:	Date Received:			
1010081-020	49B RITCHEY RD	0605	9/29/2010 6:18:00 AM	10/1/2010 9:00:00 AM			
Analyte	Result	Qual	MCL	PQL	Units	DF	Date Analyzed

Copper	0.00233		1.3	0.00102	mg/L	1	Analyst: FO 10/8/2010 10:51:12 PM
Lead	0.000414	J	0.015	0.00102	mg/L	1	10/8/2010 10:51:12 PM

## Qualifiers:

A Not Available for Accreditation	B Analyte Detected in Method Blank
E Value Above Quantitation Range	H Holding Time Exceeded
J Analyte Detected Below Quantitation Limits	N Not Accredited
S Spike Recovery Outside Recovery Limits	X Value Exceeds Maximum Contaminant Level (MCL)

PQL: Practical Quantitation Limit